

Government Of West Bengal Office Of The Divisional Fire Officer, Paschim Bardhaman West Bengal Fire & Emergency Services Asansol Fire Station, G.T. Road, P.O.:-Asansol, P.S.:-Asansol(South), Pin :- 713301

Memo no.:IND/WB/FES/20192020/84742

Date: 09-01-2024

PHARMACY EDU-BLD=1

From:

Divisional Fire Officer, Paschim Bardhaman West Bengal Fire & Emergency Services

To: Dr. B.C Roy College of Pharmacy And Allied Health Science, (A Unit of Dr. B.C Roy Engineering College). Existing G3 Educational Building at - Dr. Meghnad Saha Sarani, Biddhan nagar, Durgapur, Under D.M.C, Dist. Paschim Bardhaman, Pin-713212..

Sub: Renewal of Fire Safety Certificate for existing G+III storied operational Educational occupancy in the name and style as 'Dr. B.C Roy College of Pharmacy And Allied Health Science, (A Unit of Dr. B.C Roy Engineering College)' at Dr. Meghnad Saha Sarani, Biddhan nagar, Durgapur, Under D.M.C, Dist. Paschim Bardhaman, Pin-713212.

This is in reference to your application no. 0125191239100394 dated 29-11-2023 regarding the Renewal of Fire Safety Certificate for existing G+III storied operational Educational occupancy in the name and style as 'Dr. B.C Roy College of Pharmacy And Allied Health Science, (A Unit of Dr. B.C Roy Engineering College)' at Dr. Meghnad Saha Sarani, Biddhan nagar, Durgapur, Under D.M.C, Dist. Paschim Bardhaman, Pin-713212.

1

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

NOTE - RFSC has been issued on condition that one stand by pump to be installed within three month and intimate to this department by written.

1.Maintenance/checking testing of all fire safety installations shall be checked time to time.

2. Any nominated officer of this Department shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire Prevention and Fire Safety Measures.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191239100394.

3.Good House keeping should always be maintained.

4.Another Terrace Pump of Power 5 HP and Discharge Capacity 450 LPM at roof level in connection with OHWR shall be installed as Standby Pump in common delivery header with Main Pump.

5.Mock Drill must be performed twice in a year and recorded properly.

6. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.

7.No parking will be allowed on the Driveway.

8. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.

9.To eliminate risk of fire hazards, good house-keeping both for inside and outside of the buildings shall be strictly maintained.

10.Existing Electrical wiring of the whole industry shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.

11. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable areas of the site.

12. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.

13. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the industry.

14.A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the Industry. 15.First-Aid Fire Fighting system shall be provided as per I.S. specification.

16.Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the industry to keep them in perfectly good working condition at all the times.

17.If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.

18. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.

19. The Fire Safety Audit is to be conducted in a regular interval and to be recorded in the fire prevention maintenance register.

20. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled and no renewal would be made.

21. This Renewal of Fire Safety Certificate is valid for three years as per existing Govt. Notification and has to be renewed in due time.



Divisional Fire Officer Pachim Burdwan Division.., Paschim Bardhaman West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document' link and keying in the Unique Number: 0125191239100394.



SERVICE ORDER

Page 1 of 2

DR.B.C.ROY COLLEGE OF PHARMACY & ALLIED HEALTH SCIENCES DR.MEGHNAD SAHA SARANI, BIDHAN NAGAR, DURGAPUR-713206,WEST BENGAL

Phone: (0343) 253 2679, Fax: (0343) 253 2679, eMail: bcrcp_dgp@yahoo.co.in

| <u>Vendor Detail</u> FIRE SAFETY 15, BAGHAJA | | SERVICE ORDER NO.: SVC/BCRCP/00045/22-23 DATE : 16/03/2023 |
|--|--|---|
| DIST: PASCH | IIM BURDWAN, | Contact Detail |
| DURGAPUR | | Contact Person : |
| Phone: | 8250971143 | Telephone No. : |
| Fax: Gstin : Pan No.: | 19BOMPM8101B1Z2 BOMPM8101B | Our Fax Number: (0343) 253 2679 E-mail : bcrcp_dgp@yahoo.co.in |
| | Defiling convicing and supply of spare | parts of fire extinguisher of Boy's,Girls Hostel & BCRCP |

| | Refilling, servicing and supply of spare para | Active Unit | UOM | Gross Amount |
|----|---|-------------|-----|--------------|
| SL | Main Text | 1 | NOS | 17,300.00 |
| 1 | SERVICE CHARGES | | | |

| e ite | em covers the following services: | | UOM | Price | Amount | Completion Dt |
|---------------------|---|-------|------|---------|-----------|---------------|
| SL | Item Name | Unit | | | 3 600.00 | 19/03/2024 |
| .1 | REFILLING OF FIRE EXTINGUISHER AND SPARES | 9.00 | NOS | 400.00 | 0,000101 | |
| 2 | Refilling of ABC S/P type 2 kg capacity Fire Extinguishers REFILLING OF FIRE EXTINGUISHER AND SPARES | 1.00 | NOS | 500.00 | 500.00 | 19/03/2024 |
| 3 | Refilling of ABC S/P type 4kg capacity Fire Extinguishers REFILLING OF FIRE EXTINGUISHER AND SPARES | 12.00 | NOS | 650.00 | 7,800.00 | 19/03/2024 |
| 4 | Refilling of ABC S/P type 6 kg capacity Fire Extinguishers REFILLING OF FIRE EXTINGUISHER AND SPARES | 4.00 | NOS | 575.00 | | 19/03/2024 |
| | Refilling of CO2 type 2 kg capacity Fire Extinguishers | 2.00 | NOS | 750.00 | 1,500.00 | 19/03/2024 |
| 5 | REFILLING OF FIRE EXTINGUISHER AND SPARES Refilling of CO2 type 4.5 kg cabacity Fire Extinguishers | 1.00 | NOS | 500.00 | 500.00 | 19/03/2024 |
| | REFILLING OF FIRE EXTINGUISHER AND SPARES Refilling of DCP G/C type 5 kg capacity fire exitin | ډې | NOS | 260.00 | 780.00 | 19/03/2024 |
| 7 | REFILLING OF FIRE EXTINGUISHER AND SPARES Valve for ABC S/P type 2 kg capacity Fire | 3.00 | | | | |
| 8 | Extinguishers(Spare parts) REFILLING OF FIRE EXTINGUISHER AND SPARES Pressure gauge for ABC S/P type 2 kg capacity Fire | 2.00 | NOS | 160.00 | 320.00 | 19/03/2024 |
| | Extinguishers(Spare parts) | | | Total | 17,300.00 |) |
| | | | @ 9. | | 1,557.00 |) |
| Add - SGST-BILLWISE | | | - | 00 % | 1,557.00 |) . |
| | Add - CGST-BILLWISE | | Gran | d Total | 20,414.0 | 0 |

Twenty Thousand Four Hundred Fourteen Only In Words-Rupees:

TESRMS & CONDITIONS

1000



SERVICE ORDER

DR.B.C.ROY COLLEGE OF PHARMACY & ALLIED HEALTH SCIENCES

DR.MEGHNAD SAHA SARANI, BIDHAN NAGAR, DURGAPUR-713206,WEST BENGAL

Phone: (0343) 253 2679, Fax: (0343) 253 2679, eMail: bcrcp_dgp@yahoo.co.in

Delivery : Within 7 days from the date of receipt of Order at our college campus .

۴.

Payment : After successful delivery.

Freight : Inclusive.

PERIOD FROM 20-03-2023 TO 19-03-2024

Inn

BIDYUT KUMAR SAHA

Prepared By

J.SINGH Approved By

Receipt By

Ø FIRE SAFETY SOLUTIONS

15, BAGHAJATIN PATH, CITY CENTER, DURGAPUR, DIST.-PASCHIM BURDWAN Email ID-firesafetysolutions213@gmail.com. (M)-9746065119 / 9163493563 GSTIN-19BOMPM8101B1Z2

| TAX INVOICE | Original/Duplicate/Triplicate |
|-------------|-------------------------------|
| BILL .NO | : FSS/2022-23/49 |
| DATE | : 20-03-2023 |
| PO No | : SVC/BCRCP/00045/22-23 |
| | Dated - 16/03/2023 |
| | BILL .NO DATE |

To,

Dr.B.C Roy College of Pharmacy and Allied Health Science. Dr.Meghnad Sarani,Bidhannagar Durgapur-713206.


| S. No | SAC | DESCRIPTION OF WORK | QNTY | RATE/UNIT | AMOUNT |
|-------|------|---|---------|-----------|-------------|
| 1 | 9987 | Refilling of ABC S/P type 2 kg capacity Fire Extinguishers | 09 nos. | Rs.400.00 | Rs.3600.00 |
| 2 | 9987 | Refilling of ABC S/P type 4kg capacity Fire Extinguishers | 01 nos. | Rs.500.00 | Rs.500.00 |
| 3 | 9987 | Refilling of ABC S/P type 6 kg capacity Fire Extinguishers | 12nos. | Rs.650.00 | Rs.7800.00 |
| 4 | 9987 | Refilling of CO2 type 2 kg capacity Fire Extinguishers | 04 nos. | Rs.575.00 | Rs.2300.00 |
| 5 | 9987 | Refilling of CO2 type 4.5 kg capacity Fire Extinguishers | 02 nos. | Rs.750.00 | Rs.1500.00 |
| 6 | 9987 | Refilling of DCP G/C type 5 kg capacity Fire Extinguishers | 01 no. | Rs.500.00 | Rs.500.00 |
| | | | | Sub total | Rs.16200.00 |
| | | | | SGST@9% | Rs.1458.00 |
| | | | | CGST@9% | RS.1458.00 |
| | | | | Total | Rs.19116.00 |

In words:-Nineteen thousand one hundred sixteen only.

1) Please pay by account payee cheque/D.D/RTGS only

2) Interest @ 18% per annum will be charged on nonpayment of bill within 7 days on its submission

3) In case of disputes only Durgapur Court will have jurisdiction.



DEALS IN : ALL TYPES OF FIRE FIGHTING SERVICE PROVIDER, ISI MARKED FIRE EXTINGUISHER, SMOKE DETECTOR, REFILLINGS.

Bidynt m. Sahn.

W FIRE SAFETY SOLUTIONS

15, BAGHAJATIN PATH, CITY CENTER, DURGAPUR, DIST.-PASCHIM BURDWAN Email ID-firesafetysolutions213@gmail.com. (M)-9746065119 / 9163493563 GSTIN-19BOMPM8101B1Z2

TAX INVOICE

Original/Duplicate/Triplicate

Total

Rs.1298.00

| GSTIN : 19BOMPM8101B1Z2 | BILL .NO | : FSS/2022-23/50 |
|-------------------------|----------|-------------------------|
| PAN NO : BOMPM8101B | DATE | : 20-03-2023 |
| | PO No | : SVC/BCRCP/00045/22-23 |
| | | Dated - 16/03/2023 |

To,

Dr.B.C Roy College of Pharmacy and Allied Health Science. Dr.Meghnad Sarani,Bidhannagar Durgapur-713206.

| S. No | SAC | DESCRIPTION OF WORK | QNTY | RATE/UNIT | AMOUNT |
|-------|------|---|---------|-----------|------------|
| 1 | 8424 | Valve for ABC S/P type 2 kg capacity Fire Extinguishers | 03 nos. | Rs.260.00 | Rs.780.00 |
| 2 | 8424 | Pressure gauge for ABC S/P type 2 kg capacity Fire Extinguishers | 02 nos. | Rs.160.00 | Rs.320.00 |
| | | | | Sub total | Rs.1100.00 |
| | | | | SGST@9% | Rs.99.00 |
| | | | | CGST@9% | RS.99.00 |

In words:-one thousand two hundred ninety eight only.

1) Please pay by account payee cheque/D.D/RTGS only

2) Interest @ 18% per annum will be charged on nonpayment of bill within 7 days on its submission

3) In case of disputes only Durgapur Court will have jurisdiction.

For Fire Sg Solutions Bank Details:-10 **Fire Safety Solutions** A/C no-151811010000076 Bank Name- Union Bank Of India IFSC & Branch- City Centre Durgapur & UBIN0815187

DEALS IN : ALL TYPES OF FIRE FIGHTING SERVICE PROVIDER, ISI MARKED FIRE EXTINGUISHER, SMOKE DETECTOR, REFILLINGS.

Bridget un. Saha.

© FIRE SAFETY SOLUTIONS

15, BAGHAJATIN PATH, CITY CENTER, DURGAPUR, DIST.-PASCHIM BURDWAN Email ID-firesafetysolutions213@gmail.com. (M)-9746065119 / 9163493563

ROAD CHALLAN

FSS/DGP/03-23/57

Date-20-03-2023

To, Dr.B.C Roy College of Pharmacy and Allied Health Science. Dr.Meghnad Sarani,Bidhannagar Durgapur-713206.

Sir,

We are sending back the following Fire Extinguishers after refilling to your college: -

| S. No | DESCRIPTION OF WORK | QNTY |
|-------|---|---------|
| 1 | ABC S/P type 2 kg capacity Fire Extinguishers | 09 nos. |
| 2 | ABC S/P type 4kg capacity Fire Extinguishers | 01 nos. |
| 3 | ABC S/P type 6 kg capacity Fire Extinguishers | 12nos. |
| 4 | CO2 type 2 kg capacity Fire Extinguishers | 04 nos. |
| 5 | CO2 type 4.5 kg capacity Fire Extinguishers | 02 nos. |
| 6 | DCP G/C type 5 kg capacity Fire Extinguishers | 01 no. |

The following spares has been repaced at the time if refilling :-

| S. No | DESCRIPTION OF WORK | QNTY |
|-------|--|---------|
| 1 | Valve for ABC S/P type 2 kg capacity Fire Extinguishers | 03 nos. |
| 2 | Pressure gauge for ABC S/P type 2 kg capacity Fire Extinguishers | 02 nos. |

Kindly receive the same.

