



Government Of West Bengal
Office Of The Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O. :- Rajbati, Pin :- 713104

Memo no. FSR/0125186201701110

Date: 04-02-2022

From
Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services

To: DR B.C. ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCES(A UNIT OF DR B.C. ROY ENGINEERING COLLEGE
AT C.S PLOT NO 214(P), MOUZA- GOPINATHPUR, J.L. NO. 85, DR. MEGHNAD SAHA SARANI, BIDHANNAGAR,
P.S - DURGAPUR, DIST.- PASCHIM BARDHAMAN-713206

Sub: Fire Safety Certificate for the occupancy of an existing construction of G+4 storied building under group educational occupancy, in favour of DR B.C. ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCES(A UNIT OF DR B.C. ROY ENGINEERING COLLEGE, at the Premises/Holding no. AT C.S. PLOT NO. 214(P), MOUZA- GOPINATHPUR, J.L. NO. 85, DR. MEGHNAD SAHA SARANI, BIDHANNAGAR, P.S. - DURGAPUR, DIST.- PASCHIM BARDHAMAN-713206.

This is in reference to your application no. 0125189229100019 dated 01-02-2022 regarding the Fire Safety Certificate for the occupancy of an existing construction of G+4 storied building under group educational occupancy, in favour of DR B.C. ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCES(A UNIT OF DR B.C. ROY ENGINEERING COLLEGE, at the Premises/Holding no. AT C.S. PLOT NO. 214(P), MOUZA- GOPINATHPUR, J.L. NO. 85, DR. MEGHNAD SAHA SARANI, BIDHANNAGAR, P.S. - DURGAPUR, DIST. - PASCHIM BARDHAMAN-713206.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building

Recommendation:

1 All the Fire Safety Recommendations/Revised Fire Safety Recommendations which were issued vide this Office Memo No. FSR/0125186201701110, be followed strictly at all time.

2 Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way

3 U G W R shall be increases per recommendation. Adequate nos. ring main hydrant system with adequate nos. of delivery hose & hose box, 2 nos. 2 way fire service inlet, in addition to the existing installation, another 30HP sb pump as marked in the plan drawing & recommendation shall be made within three month from the date of receipt this certificate

Violation if any this certificate treated as cancel

4 The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.


The authenticity of this document can be verified by accessing the URL: district.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Certificate Number: 0125189229100019

Page: 1

Powered By



For secure paper transactions
Please visit www.wb.gov.in
Dr. N. S. Ghosh, Ph.D (J.U.)
Principal
Durgapur, West Bengal-713205



- 5 To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained
- 6 A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building
- 7 A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building
- 8 If required old line shall have to be replace with new lines, the cables shall always be laid in M.S conduit pipes continuously bonded to the earth
- 9 Existing lifts shall be treated as fire lift in case of emergency
- 10 Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above mentioned system.
- 11 Fire License shall have to be obtained for storing and processing with L.P.G and other highly combustibile articles
- 12 Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them particularly lines above false ceiling and ducts
- 13 Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
- 14 First aid firefighting system shall be provided as per I.S specification
- 15 The notice of firefighting and evacuation from the building shall be prepared and displayed at all vurnalable place of the building
- 16 The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing
- 17 Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building
- 18 Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipments installed in the building to keep them in perfectly good working conditions at all times
- 19 The Fire Safety Certificate is valid for a period of three years from the date of issue and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid
 Digitally signed by PULACK SHARMA
 Date: 2022.02.24 21:19:43 IST

Divisional Fire Officer, Paschim Bardhaman
 West Bengal Fire & Emergency Services


 Prof. (Dr.) Samir Kumar Samanta
 M. Pharm., Ph.D (J.U.)
 Principal
 D. B. C. Roy College of Pharmacy & AHS
 Durgapur, West Bengal-713206