

Annual Report for Fire Safety

Annual report (2016-2017)

Renewal of fire safety certificate was received from the Divisional Fire Officer, Burdwan Division, West Bengal Fire and Emergency Services with Memo No. FES/Bdn/9/4/2017 on 5th of May 2017 for the running G+3 storied building in favor of the college. The system incorporation was done and few safety measures were told to maintain.

All the positions of the cylinders with specific capacity particulars in several locations of the building were maintained properly. Refilling dates and expiry dates were documented.

Few meetings took place for several purposes. The agendas were mainly to generate awareness including knowledge of the equipment, to check the expiry dates of the extinguishers with all the fire alarms for better safety. Minutes of the meeting was mainly to generate awareness among all the students, staffs and faculty members. Moreover, some corrective measures and recommendations for correcting the hazards were also discussed. Mock drilling was done as well for safety checking.



Annual report (2017-2018)

Fire safety committee added one new member with six other members. Few meetings were held with specific agendas in which some are, sensitizing every employee and students and preparing them for the worst. Safety circles were also decided to be very important for each year. Fire safety installations Fire protection systems consisting of Hydrants, hose pipes, smoke alarms, sprinklers, extinguishers etc. that were installed were checked, operated and maintained in the entire premises in accordance the statutory requirements.



Annual report (2018-2019)

Renewal of fire safety certificate was received from the Divisional Fire Officer, fire prevention wing, West Bengal fire and Emergency Services with Memo No. IND/WB/FES/20182019/22703 on 14th of September 2018. Few recommendations like testing of electrical load and earthing, checking of electrical wiring to avoid loose contact of the wires were proposed. Safety measures like to ensure there is no spillage or leakage of any flammable/ fuming/ toxic/ corrosive chemicals and to preserve them in seal container was assured. Minutes of the meeting was mainly to generate awareness among all the students, staffs and faculty members regarding the knowledge of the equipment, checking of the expiry dates, and fire safety alarms etc. Mock drill was done in a routinized form.



Annual report (2019-2020)

Three more fire cylinders were purchased in this year with a spare siphon tube in the month of July in 2020. Several safety measures were taken along with the refilling of the cylinders. For Covid-19 lockdown college was closed but the required measures were taken accurately. Mock Drill was done accordingly with staffs and faculties.



Annual report (2020-2021)

For Covid-19 lockdown it was not totally possible to make aware of all the fire facilities for the students and the staffs. But refilling of the cylinders and mock drill was done accordingly.



**Dr.B.C.Roy College of
Pharmacy and Allied
Health Sciences**

www.bcrp.ac.in | www.bcrp.net



Ph: (0343) 253 2679
Telefax: (0343) 253 2679
e-mail: bcrp_dgp@yahoo.co.in

Dr. Meghnad Saha Sarani, Bidhannagar, Durgapur-713206, West Bengal

Approved by AICTE, PCI & Affiliated to the Maulana Abul Kalam Azad University of Technology, West Bengal (Formerly WBUT) and WBSCT&VE&SD

Fire alarms and pressure pump was installed in the education building-II and the operations were demonstrated. New Hose pipe was also installed in the education building-II. All the new facilities were understood by the members of Fire Safety Committee.

S. Chakraborty 16/11/21

Dr. Santanu Chakraborty

In-charge, Fire Safety Committee

Dr. B. C. Roy College of Pharmacy and AHS

Boys
17/11/21

Principal
Dr. B. C. Roy College of Pharmacy & A.H.S,
Bidhannagar, Durgapur-713206, Burdwan