

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIVISIONAL FIRE OFFICER  
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20192020/84742

DATE: 23/02/2020

From :

The Divisional Fire Officer  
Fire Prevention Wing,  
West Bengal Fire & Emergency Services.


To :


DR B C ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCES A UNIT OF  
DR B C ROY ENGG COLLEGE  
DR MEGHNAD SARANI, BIDHANNAGAR  
DURGAPUR 06 PASCHIM BURDWAN  
Durgapur FS Durgapur PS Paschim  
Bardhaman 713206  
Durgapur F.S., Durgapur PS,  
Paschim Bardhaman - 713206 .

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.-DR.B.C.ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCE, A UNIT OF DR B,C,ROY ENGINEERING COLLEGE at DR MEGHNAD SAHA SARANI, BIDHANNAGAR DURGAPUR 06 PASCHIM BURDWAN Durgapur FS Durgapur PS Paschim Bardhaman 713212, Durgapur PS, Paschim Bardhaman - 713212

This is in reference to your Application No. IND/WB/FES/20192020/84742, dated 23/02/2020, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.-DR B.C.ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCE, A UNIT OF DR B,C,ROY ENGINEERING COLLEGE at DR MEGHNAD SAHA SARANI, BIDHANNAGAR DURGAPUR 06 PASCHIM BURDWAN Durgapur FS Durgapur PS Paschim Bardhaman 713212, Durgapur PS, Paschim Bardhaman - 713212.

The performance of the Fire Fighting System as incorporated in the buildings were tested at




  
*Principal*  
Dr. B. C. Roy College of Pharmacy & A.H.S.  
Bidhannagar, Durgapur-713206, Bardwan

random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. The interior finish decoration of building made with low flame spread material confirming I S specification.
3. To eliminate risk of fire hazards, good house keeping both for insides and outside of building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any where and tear in them, particularly lines above false ceiling & ducts.
5. The fire check door shall be sealed with rubber sealing properly in order to prevent the percolation of smoke.
6. A fire control room including a close circuit T.V system preferably will have to be installed which will observe the building.
7. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
8. Floor numbers and directional sign of escape route shall be displayed prominently.
9. Mock fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. First AID Fire Fighting system shall be provided as per I S Specification.
11. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the building to keep them in perfectly good working condition at all the times.
12. Fire License shall have to be obtained for storing and processing with L P G and other combustible articles.
13. All the employees including the managerial staffs shall have adequate knowledge of using fire extinguisher and action to be taken for evacuation of building in case of emergency.
14. The Fire Safety Certificate is valid for a period of 3 years from the date of issued, and has to be renewed after 3 years, certifying about the satisfactory services, performance of all the Life and Safety arrangements and installation of the building.




  
Principal  
Dr. B. C. Roy College of Pharmacy & A.H.S.  
Bidhannagar, Durgapur-713206, Burdwan

Digitally signed  
by SUBHABRATA RAY  
Date: 2021.03.25  
16:32:27 +05'30'

Signature invalid  
Digitally signed by NITAI CHATTOPADHYAY  
Date: 2020.02.23 13:07:57 IST



  
Principal  
Dr. B. C. Roy College of Pharmacy & A.H.S.  
Bidhannagar, Durgapur-713206, Burdwan



Government Of West Bengal  
Office Of The Divisional Fire Officer, Paschim Bardhaman  
West Bengal Fire & Emergency Services  
Bhangakhuti, Purba Burdwan, P O - Rajbati, Pin - 713104

Memo no FSR/0125186201701110

Date 04-02-2022

From  
Divisional Fire Officer, Paschim Bardhaman  
West Bengal Fire & Emergency Services

To: DR B C. ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCES(A UNIT OF DR B C ROY ENGINEERING COLLEGE  
AT C.S. PLOT NO 214(P), MOUZA- GOPINATHPUR, J.L. NO. 85, DR. MEGHNAD SAHA SARANI, BIDHANNAGAR, P.S. - DURGAPUR, DIST. - PASCHIM BARDHAMAN-713206.

Sub: Fire Safety Certificate for the occupancy of an existing construction of G+4 storied building under group educational occupancy, in favour of DR B C. ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCES(A UNIT OF DR B C ROY ENGINEERING COLLEGE, at the Premises/Holding no. AT C S PLOT NO 214(P), MOUZA- GOPINATHPUR, J.L. NO. 85, DR. MEGHNAD SAHA SARANI, BIDHANNAGAR, P.S. - DURGAPUR, DIST. - PASCHIM BARDHAMAN-713206.


This is in reference to your application no. 0125189229100019 dated 01-02-2022 regarding the Fire Safety Certificate for the occupancy of an existing construction of G+4 storied building under group educational occupancy, in favour of DR B C. ROY COLLEGE OF PHARMACY AND ALLIED HEALTH SCIENCES(A UNIT OF DR B C ROY ENGINEERING COLLEGE, at the Premises/Holding no. AT C S PLOT NO 214(P), MOUZA- GOPINATHPUR, J.L. NO. 85, DR. MEGHNAD SAHA SARANI, BIDHANNAGAR, P.S. - DURGAPUR, DIST. - PASCHIM BARDHAMAN-713206.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

**Recommendation:**

- 1 All the Fire Safety Recommendations/Revised Fire Safety Recommendations which were issued vide this Office Memo No. FSR/0125186201701110, be followed strictly at all time.
- 2 Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
- 3 U.G.W.R shall be increases per recommendation. Adequate nos. ring main hydrant system with adequate nos. of delivery hose & hose box, 2 nos. 2 way fire service riser, in addition to the existing installation, another 30HP sb pump as marked in the plan drawing & recommendation shall be made within three month from the date of receipt this certificate. Violation if any this certificate treated as cancel.
- 4 The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.

The authenticity of this document can be verified by accessing the URL: [eoffice.wb.gov.in](http://eoffice.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number: 0125189229100019 Page: 1



Powered By

For secure paperless solutions  
Signer please visit [www.emsignet.com](http://www.emsignet.com)

Principal


Dr. B. C. Roy College of Pharmacy & A.H.S.  
Bidhannagar, Durgapur-713206, Burdwan

- 5 To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained
- 6 A fire control room including a closed-circuit TV system will have to be maintained which observe all floor of the building
- 7 A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building
- 8 If required old line shall have to be replace with new lines. the cables shall always be laid in M S conduit pipes continuously bonded to the earth
- 9 Existing lifts shall be treated as fire lift in case of emergency
- 10 Periodical flushing of water in the hydrant and sprinkler pipe line shall be made to maintain the efficiency working performance of above mentioned system
- 11 Fire License shall have to be obtained for storing and processing with L.P.G. and other highly combustible articles
- 12 Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them particularly lines above false ceiling and ducts
- 13 Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I S specification
- 14 First aid firefighting system shall be provided as per I S specification
- 15 The notice of firefighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building
- 16 The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing
- 17 Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building
- 18 Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times
- 19 The Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Signature valid

Digitally signed by PURACK  
SHARMA  
Date: 2022.02.24 21:19:43 IST

Divisional Fire Officer, Paschim Bardhaman  
West Bengal Fire & Emergency Services



Powered By



For secure paperless solutions  
Please visit [www.emsigner.com](http://www.emsigner.com)

Principal

Dr. B. C. Roy College of Pharmacy & A.H.S.  
Bidhannagar, Durgapur-713206, Burdwan